

December 23, 2022

Terrence Williams, General Manager

**ADDENDUM NO. 2
TO THE CONTRACT DOCUMENTS**

**Humboldt Community Services District
5055 Walnut Drive
Eureka, CA 95503
BRIER LANE TANK REHABILITATION PROJECT**

TO ALL PLAN HOLDERS

The following amendment is hereby made a part of the Contract Documents for the subject project, as fully and completely as if the same were set forth therein. This Addendum No. 2 consists of page AD1-1.

CONTRACT DOCUMENTS

QUESTIONS SUBMITTED:

Question 1. Is full containment required for exterior abrasive blasting and coating?

Answer 1. The contractor is not required to provide full containment. The contractor shall be required to conduct all operations to confine abrasive blasting debris and coating and paint overspray to within the bounds of the site in accordance with Specification Section 09 97 13, Item 1.5 C., Item 3.2 E., and Item 3.3 C.

Bids submitted without these pages signed, dated, and attached may be rejected. If you have any questions or comments, contact Krista Harper at (951) 372-9196.

Received by:

Contractor: _____ Date: _____

Signature: _____

Sincerely,

Terrence Williams
General Manager

